

**TABLE R301.2 CLIMATIC AND GEOGRAPHIC DESIGN CRITERIA**

GROUND SNOW LOAD <sup>a</sup> (psf)	WIND DESIGN		SEISMIC DESIGN CATEGORY <sup>d</sup>	SUBJECT TO DAMAGE FROM			ICE BARRIER UNDERLAYMENT REQUIRED	FLOOD HAZARDS	AIR FREEZING INDEX <sup>f</sup>	MEAN ANNUAL TEMP <sup>g</sup>
	Speed <sup>b</sup> (mph)	Topographic effects Special region Debris <sup>c</sup>		Weathering <sup>e</sup>	Frost line depth	Termite				
155	105	No	B	Severe	36"	Slight	Yes	n/a	3500	35°F

**MANUAL J DESIGN CRITERIA<sup>i</sup>**

Elevation	Latitude	Altitude correction factor <sup>h</sup>	Indoor winter design dry-bulb temperature	Outdoor winter design dry-bulb temperature <sup>i1</sup>
9,400'	38.9122 °N	Varies	68°F	-16°F
Daily range	Coincident wet bulb <sup>i2</sup>	Indoor summer design relative humidity & Summer design gains	Indoor summer design dry-bulb temperature	Outdoor summer design dry-bulb temperature <sup>i3</sup>
High	60°F	n/a	75°F	87°F

- a. Ground snow load per 2016 SEAC Colorado Design Snow Loads, to be used calculations in ASCE 7-16.
- b. In accordance with [Figure R301.2\(2\)](#). Value is nominal design 3-second gust wind speed in miles per hour (m/s) at 33 feet (10 m) above ground for Exposure C Category for Risk Category II Buildings. Value should be adjusted per ASCE 7-16 for different Risk Categories.
- c. In accordance with [Section R301.2.1.2](#).
- d. Per ASCE 7-16 Hazard tool with Risk Category II and Site Soil Class C.
- e. Weathering severity is per [Figure R301.2\(1\)](#). The grade of masonry units shall be determined from ASTM C34, ASTM C55, ASTM C62, ASTM C73, ASTM C90, ASTM C129, ASTM C145, ASTM C216 or ASTM C652.
- f. Per the 100-year return period air freezing index (BF-days) from [Figure R403.3\(2\)](#) or from the 100-year (99 percent) value on the National Climatic Data Center data table “Air Freezing Index-USA Method (Base 32°F).”
- g. Per the National Climatic Data Center data table “Air Freezing Index-USA Method (Base 32°F).”
- h. This value varies depending on equipment type and system configuration. Per Equipment Manufacturer/Design Professional.
- i. Design criteria for load calculations ([ACCA](#) Manual J or other method permitted by the jurisdiction.) Values are per the 2021 ASHRAE Handbook — Fundamentals. World Meteorological Organization station 724677, Gunnison Airport.
  - i1. Reflects the 99.6% Heating dry bulb temperature.
  - i2. Reflects the mean annual maximum Cooling wet bulb temperature.
  - i3. Reflects the mean annual maximum Cooling dry bulb temperature.